

CERTIFICATE OF CONFORMITY – PORTABLE FIRE EXTINGUISHERS

Certificate of conformity reference number: **KB 150/17**

Test specification: **EN 3-7 : 2004 + A1 : 2007**

Test report no.: **20170868/EM 24**

Requested by: **Emme Antincendio S.r.l., Via del Molino, 40, 52010 CORSALONE (AR), ITALY**

Manufacturer: **Emme Antincendio S.r.l., Via del Molino, 40, 52010 CORSALONE (AR), ITALY**

Model name: **21021-1**

Trade mark: **EMME**

Assembly drawing no.: **21021-1**

List of parts no.: **21021-1**

Fire extinguishing medium: **2 kg EPW 18462**
Reference no. –

Operation device: **Grip lever**

Propellant: **15 bar / 20 °C, compressed air**

Special detail: **Nozzle Ø 3,3 mm**

Test fire rating: **13 A and 89 B according to EN 3-7**

Range of operating temperature: **-30 °C to 60 °C**


Notes: –

Conformity to the above mentioned test specification is attested. All applicable requirements have been met.

This certificate of conformity is valid solely for fire extinguishers which correspond to the submitted test samples and to the confirmed documents.

This certificate of conformity does not include surveillance.

16th October, 2017



Grad. Eng. Jürgen Dittrich
Laboratory Manager



MPA Dresden GmbH
Fuchsmühlenweg 6F
09599 Freiberg
www.mpa-dresden.de

Geschäftsführer: Thomas Hübler
Tel. +49(0)3731-20393-0
Fax +49(0)3731-20393110
E-Mail info@mpa-dresden.de

Amtsgericht Chemnitz HRB 28268
Steuernummer: 220/114/03364
USt-IdNr. DE291271296

Sparkasse Mittelsachsen
Poststraße 1a
09599 Freiberg
IBAN DE68 870520003115024672
BIC WELADED1FGX

DICHIARAZIONE DI CONFORMITÀ – ESTINTORI PORTATILI

N. pratica della dichiarazione di conformità: **KB 150/17**

Norme di
riferimento per il
controllo:

EN 3-7 : 2004 + A1 : 2007

Verbale di prova n.: 20170868/EM 24

Committente: Emme Antincendio S.r.l., Via del Molino, 40, 52010 CORSALONE (AR), ITALY

Produttore: Emme Antincendio S.r.l., Via del Molino, 40, 52010 CORSALONE (AR), ITALY

Modello: 21021-1

Marchio di fabbrica: EMME

Disegno n.: 21021-1

Distinta n.: 21021-1

Agente estinguente: 2 kg EPW 18462
N. pratica –

Dispositivo di azionamento: Premendo una leva

Propellente: 15 bar / 20 °C, aria compressa

Modello speciale: Ugello Ø 3,3 mm

Capacità
estinguente: 13 A e 89 B conforme EN 3-7

Campo di temperatura di
funzionamento: da -30 °C a 60 °C


Note: In caso di controversie farà fede solamente la versione in lingua inglese della presente dichiarazione di conformità.

Si attesta la conformità alle suddette norme di riferimento. Tutti i requisiti previsti sono stati soddisfatti

La presente dichiarazione di conformità ha validità solamente con riferimento ad estintori conformi ai campioni inviati per il controllo e alla documentazione oggetto di conferma.

La presente dichiarazione di conformità non include un monitoraggio da parte di terzi.

Freiberg, 16 ottobre 2017



Dipl.-Ing. Jürgen Dittrich
Direttore dell'ente di controllo



MPA Dresden GmbH
Fuchsmühlenweg 6F
09599 Freiberg
www.mpa-dresden.de

Geschäftsführer: Thomas Hübler
Tel. +49(0)3731-20393-0
Fax +49(0)3731-20393110
E-Mail info@mpa-dresden.de

Amtsgericht Chemnitz HRB 28268
Steuernummer: 220/114/03364
USt-IdNr. DE291271296

Sparkasse Mittelsachsen
Poststraße 1a
09599 Freiberg
IBAN DE68 870520003115024672
BIC WELADED1FGX