Bauaufsichtlich anerkannte Prüf-, Überwachungs und Zertifizierungsstelle Amtlich anerkannte Prüfstelle für Feuerlöschmittel und -geräte DIN EN ISO/IEC 17025: DAP-PL-1137.00; DIN EN 45011: DAP-ZE-4348.00; DIN EN 17020: DAP-IS-4347.00 ZI.S-P-860/09; ZLS-ZE-707/09 Notified Body no. 0767 Mitglied des VMPA e.V.



CERTIFICATE

Fire extinguishers

This is to confirm that the below stated "BAVARIA" DIN EN 3 fire extinguisher with 2 kg ABC dry chemical powder is approved in accordance with DIN EN 3-7 as well as on basis of the available test reports for fire extinguishing purposes for the fire classes A, B and C according to DIN EN 2 under the following certification number:

SP 86/10

Test report according to annex C of EN 3-10, No.: 2009-F-2264/EG 90

Holder of certificate: BAVARIA EGYPT S.A.E., 17, Emad El Din St., 11111 Cairo, Egypt

Manufacturer: BAVARIA EGYPT S.A.E., Gisr El Suez St. Block 109-Industrial Zone,

Ismailia Desert Road, 11511 Cairo, Egypt

Model name of the fire extinguisher: Tigra 2 Drawing No.: 20 T2020 Component list No.: 20 T2020

Fire extinguishing Operation device: Pulling (safety)

medium: ABC BAVARIA EXTRA POWDER device and key

Cert. No. SP 67/09

Propellant: 28 g CO₂, internal cartridge Special detail: Nozzle diameter 5,0 mm

operation range: -30 °C to 60 °C

Information: The plastics operation device is tested according to EN 3-8, test report No. 2000-23-162/EG 18.

Temperature

The fire extinguisher is tested in accordance with DIN EN 3. Conformity to DIN EN 3 is confirmed.

13 A and 89 B according to DIN EN 3-7

The given certification number SP 86/10 is to state in section 4 of the extinguisher label according to DIN EN 3-7.

This certificate is valid for fire extinguishers only, those comply with the submitted documents and test samples.

This certificate is valid for fire extinguishers only, those are subjected to a quality assurance system during manufacture.

The quality assurance system shall include the valid requirements of the standard DIN EN 3 concerning factory production control.

The holder of certificate is entitled to put up the above stated certification number on the fire extinguisher as long as the results of our regular inspection of manufacture in accordance with DIN EN 3 are satisfactory.

Schungs- und Zertiff

The above mentioned European standards relate to the editions which were valid at the date of this certification.

31 May 2010

Test fire rating:

Grad. Eng. A. Ullmann Manager of the certification office

MPA Dresden GmbH Fuchsmühlenweg 6F 09599 Freiberg

Tel. +49(0)3731-20393-0 Fax +49(0)3731-20393110 Geschäftsführer: Thomas Hübler Steuernummer: 220/114/03011 Amtsgericht Chemnitz HR B 21581

www.mpa-dresden.de Email_info@mpa-dresden.de Kreissparkasse Freiberg Poststraße 1a 09599 Freiberg Kto. 3115024672 BLZ 870 520 00 USt-IdNr. DE234220069 IBAN DE68 8705 2000 3115 0246 72 BIC_WELADED1FGX



